

No. NACCWX25033343

运输危险性鉴定报告

Identification and Classification Report for Transport

(海运)

非限制性货物

样品名称: 压缩式热泵 (X23-10P)
Name of Goods : SWIMMING POOL HEAT PUMP/AIR TO WATER HEAT PUMP (X23-10P)

委托单位: 佛山市顺德区一拓电气有限公司
Applicant: YITUO ELECTRIC CO., LTD

广东省科学院测试分析研究所(中国广州分析测试中心)
Institute of Analysis, Guangdong Academy of Sciences
(China National Analytical Center, Guangzhou)



扫一扫 查一查

声明 Statement

1. 本报告依据现行有效的国际海事组织《国际海运危险货物规则》、委托人(托运人或其代理人)提供的物品及其相关信息出具。

This report is issued according to IMDG Code valided in the current year, the information of the goods and its shipment provided by the applicant (shipper or his agent).

2. 本报告的鉴定结论仅对委托方送检/提供的样品负责。委托方保证申报的物品和/或提供的样品与交运的货物一致, 由于委托方提供的样品及其信息不真实而导致的一切后果均由委托方负责。

The conclusion of this report is responsible only for the sample provided by the applicant. The applicant guarantees that the declared goods and/or the sample who provides should be identical with the contents of cargo that is to be transported. The applicant should undertake the law responsibility that result from providing untruth sample and untruth information.

3. 本报告经主检人、审核人、批准人签字或签章并加盖广东省科学院测试分析研究所(中国广州分析测试中心)印章后生效。

This report will be effective only after it is signed or stamped by the Appraiser, Checker, Approver, and stamped by Institute of Analysis, Guangdong Academy of Sciences (China National Analytical Center, Guangzhou).

4. 本报告私自转让、复制、盗用、冒用、涂改、或以任何媒体形式篡改的均属无效。

The report is invalid when anything of the following happens - illegal transfer, reproduction, embezzlement, imposture, modification or tampering in any media form.

5. 本报告不考虑国家及经营人差异。

The report takes no account of the state and operator variations.

6. 本报告当年有效。

The report is only valid in the year subscribed on it.



地址: 广东省广州市先烈中路100号大院34号楼, 510070

Address: Building 34, No.100, Xianlie Middle Road, Guangzhou, Guangdong, China, 510070

电话(Tel): (008620) 37656892, 87683647 传真(Fax): (008620) 87685550

邮箱(Email): 87683647@fenxi.com.cn 网址(Website): <http://www.fenxi.com.cn>



微信公众号

运输危险性鉴定报告

No. NACCWX25033343

Identification and Classification Report for Transport

样品名称 Name of Goods	压缩式热泵 (X23-10P) SWIMMING POOL HEAT PUMP/AIR TO WATER HEAT PUMP (X23-10P)		
委托单位 Applicant	佛山市顺德区一拓电气有限公司 YITUO ELECTRIC CO., LTD		
生产单位 Manufacturer	佛山市顺德区一拓电气有限公司 YITUO ELECTRIC CO., LTD		
样品编号 Sample No.	WXST2513413-004	委托日期 Accepting Date	2025-12-23
鉴定日期 Inspection Date	2025-12-23 ~ 2025-12-28	生效日期 Effective Date	2026-01-01
样品描述 Appearance & properties	纸箱包装件, 含1台热泵(型号: X23-10P, 内充装750g制冷剂R290, 和无色液体, 稍有气味), 外包装尺寸(mm): 993×450×690 Cardboard box packaging, containing one heat pump(model:X23-10P, internally charged with 750g of refrigerant R290 and colorless liquid, weak odor), outer packaging size (mm):993×450×690		
鉴定结论 Conclusion	不受IMDG Code 限制, 可按非限制性货物办理。 满足IMDG Code条款291的相关要求。 样品所含液体不属于易燃液体。样品含制冷剂R290, 其装载量为750 g。 Not subject to IMDG Code. Meet the requirements of the provision 291 of IMDG Code. The liquid contained in the sample does not belong to flammable liquid. The sample contains refrigerant R290, the quantity of which is 750 g.		
建议比照条目 Suggestion for Dangerous Goods Transportation	不受IMDG Code限制, 可按非限制性货物办理。 Not subject to IMDG Code.		
鉴定依据 Criteria	国际海运危险货物规则(2024 版) IMO IMDG Code (2024 Edition)		
运输信息 Transportation Informations	——		
备注 Note	——		

报告签发日期 Issue Date: 2025-12-28

主检:
Appraiser

杨光

审核:
Checker

周磊

批准:
Approver

何书琴

